

Strand Theatre Shelbyville, Inc.

Old Website Article Backup

Articles prior to December 5, 2018

Major Disaster Averted

Written by David on December, 15 2011

After the Shelby County Players struck their set the past Sunday, we noticed a curtain in the dressing area under the stage was wet. We thought that someone had opened the facet located in the dressing area starting it to leak. We were wrong! The facet started to leak because there was a major hole in the MAIN WATER LINE. Had the facet not leaked, we wouldn't have seen it until it was too late. There was a piece of rust keeping the hole plugged. As soon as we move it the rust fell out, fortunately by that time we had the water to the building completely off.

As you can see by the picture, we averted a major disaster! The fates are smiling upon the Strand.

Images on this post:



Archive File: 2011-12-15_major-disaster-averted.pdf

©2022 - Strand Theatre Shelbyville, Inc.