

Strand Theatre Shelbyville, Inc.

Old Website Article Backup

Articles prior to December 5, 2018

Oh No!

Written by Jacob on December, 19 2012

Just before the Rockphoria show on Saturday night December 15th, we noticed our marquee flood lights were flickering. This is not good in a 96 year old theatre. A quick investigation found that the breaker for these lights had failed. Fortunately we had a spare ready to go. Within a few minutes the breaker was changed and we were back in business. The Strand now has on its ?to-do? list to replace all the breakers in that panel. This is the third time this has happened. In a few weeks a little preventative maintenance will solve this problem!

Images on this post:



Archive File: 2012-12-19_oh-no!.pdf

©2022 - Strand Theatre Shelbyville, Inc.